VOLTMETER EVM-3 / EVM-3C

≡Z-TRAUQ INC.**≡**

Precautions For Installation and Safe Use

Failure to follow those instructions will result in death or serious injury.

- Disconnect all power before working on equipment.
- When the device is connected to the network, do not remove the front
- Do not try to clean the device with solvent or the like. Only clean the device with a dried cloth.
- Verify correct terminal connections when wiring.
- Electrical equipment should be serviced only by your compedent seller.
- •Only for rack panel mounting.

No responsibility is assured by the manufacturer or any of its subsidiaries for any consequences arising out of the use of this

EVM-3 (Voltmeter):

EVM-3 is designed for accurate measuring of the AC RMS voltage and for saving the minimum and maximum values of the measured voltages. Minimum and maximum values of the measured voltages supply is and maximum values remain stored in the memory when the power supply is off. This stored values can be read when the power is on. Although EVM-3 is mainly used for electrical panels, this device can also be used with any application in which accurate voltage readings should be done between 10-600V. The measurement (3-4) and power supply (1-2) connections are located on the rear panel and the digital display is centered on the front panel. **EVM-3C (Setpointed Voltmeter):**

EVM-3C (setpointed voltmeter):

EVM-3C has the same functions of the EVM-3. In addition to these functions, an high voltage level and "time delay" can be set. When the measured voltage is over the high set point value, the output relay is activated at the end of the adjusted time delay, generates an alarm signal and display starts blinking. Note: If the measurement that the device made or the primary value is over

Note: If the measurement that the device made or the primary value is over 9999 V, k led on the device is on.

Note: If the voltage on the measurement input of the device is over 600 V or measurement according to the ratio of entered primary/seconder is over 999.000 V, there will be "h" on the display.

Voltage Transformer Ratio: Voltage transformer can regulate the primary and secondary voltage values separately. Primary value can be entered between 1-40.000 and the secondary value can be entered between 1-250.

Note: If the primary and secondary values changed, control the setpoint and hysterisis values. This is important for the device working the way that it was arranged.

Minimum and Maximum Voltage:

The minimum and maximum voltage values are stored. User may read or delete these values. Stored minimum and maximum voltage values remain stored, when the power supply is off.

Setpoint (5Ph ve5P L): When the AC current which flows through the device is over the high setpoint value or it is under the low setpoint value, the output relay is switched on in order to generate an error signal at the end of programmed delay time (The point which is on the below right corner of display blinks). If the AC current value returns within preset limits, before the end of the delay

time, the relay resets itself and no tripping occurs. **Latch Function (LREC):** Latch function is used to select the output relay operation mode. Either "oF" or "on" position may be selected.

• At position "oF": If the current value returns to preset limits, output relay is

switched off At position "on": Even if the current value returns to preset limits, output relay

remains switched on and switches off only by pressing the "Set" button. Instant Tripping (ErP): If the AC current value is over the 1,5 times of setting value or it is under the 0,5 times of setting value, the output relay is switched on without any delay time. This function is user-selectable.

Setting of Voltage Transformer Primary Voltage Value (for EVM-3C)



ge Transformer Secondary Voltage Value (for EVM-3C)

| setting or voita | ge Transformer Secondary voltage v | alue (for Ex |
|------------------|---|--------------|
| SET | Press the SET button for 3 sec. | Pri |
| | Press UP or DOWN buttons until SEC is displayed. | SEC |
| SET | Press SET button. | 0250 |
| | Press <i>UP</i> or <i>DOWN</i> buttons until requested value is displayed. (If buttons are pressed continuously, displayed value is changed quickly). | 0225 |
| (SET) | Press SET button to save. | |
| Setting of High | Setpoint Value (for EVM-3C) | |
| OFT. | D " OFT! " (0 | |

auickly)

SET



Press SET button to save.

Setting of Low Setpoint Value (for EVM-3C)



Setting of Hysteresis Value (for EVM-3C)



| Setting of On Tir | ne Value (for EVM-3C) | |
|-------------------|--|----------|
| SET | Press the SET button for 3 sec. | Pri |
| | Press \emph{UP} or \emph{DOWN} buttons until $\emph{on } \emph{t}$ is displayed. | on b |
| (SET) | Press SET button. | (2.12.2) |
| | Press UP or DOWN buttons until requested value is displayed. (If buttons are pressed | (0.01) |
| | continuously, displayed value is changed quickly). | (0 15.0) |
| SET | Press SET button to save. | |

Setting of Off Time Value (EVM-3C için)



Setting of Instant Tripping Function (for EVM-3C)

| Set | Press the SET button for 3 sec. | Pri |
|-----|---|-------|
| | Press UP or DOWN buttons until trP is displayed. | (trP) |
| Set | Press SET button. | |
| | Press UP or DOWN buttons until requested value is displayed. (If buttons are pressed continuously, displayed value is changed quickly). | oF) |
| Set | Press SET button to save. | |

| — | quickly). | |
|-----------------|---|---------------------|
| Set | Press SET button to save. | |
| Setting of Lato | h Function (for EVM-3C) | |
| Set | Press the SET button for 3 sec. | Pri |
| | Press UP or DOWN buttons until LAtC is displayed. | (AFC) |
| Set | Press SET button. | (oF) |
| | Press UP or DOWN buttons until requested value is displayed. (If buttons are pressed continuously, displayed value is changed quickly). | on |
| Set | Press SET button to save. | |
| Displaying and | Deleting Tripping Number (for EVM-3 | C) |
| Set | Press the SET button for 3 sec. | (ρ_{Γ_1}) |

| Set | Press SET button. | (عو |
|---------------------------------------|---|--------|
| | Press UP or DOWN buttons until requested value is displayed. (If buttons are pressed continuously, displayed value is changed quickly). | on |
| (Set) | Press SET button to save. | |
| Displaying and | Deleting Tripping Number (for EVM-3 | C) |
| Set | Press the SET button for 3 sec. | Pri |
| | Press UP or DOWN buttons until oP is displayed. | 90 |
| Set | Press SET button. | (2000) |
| $\stackrel{\bullet}{\hookrightarrow}$ | Press UP button to delete tripping number, else do not press any button. | 0000 |

Press **SET** button to save.

VOLTMETER EVM-3 / EVM-3C

Setting of Contact Situation (for EVM-3C)



Escaping the Set Menu (for EVM-3C)




Displaying Minimum Voltage

| \bigcirc | Press and hold the DOWN button to see. (for EVM-3C) |
|------------|--|
| \Diamond | Press one time to see the minumum voltage value. (for EVM-3) |

Displaying Maximum Voltage

| (\land) | Press and hold the <i>UP</i> button to see. (for EVM-3C) |
|------------|--|
| \bigcirc | Press two time to see the maximum voltage value. (for EVM-3) |

Deleting the Minimum and Maximum Voltages




• The decimal point blinks while the display shows demand values (for EVM-3).

Factory Setting:

Voltage transformer primary voltage value (Pr.) : Voltage transformer secondary voltage value (SEC) : High set point value (SP h) : : 0100 0100 250.0 Low set point value (SP L) 150.0 Hysteresis value (h95) 010.0 On time (on t) 010.0 Off time (of £) 010.0 Instant tripping function (L-P) on Latch function (LALC) οF : no (Normaly open) Contact situation (out)

Connection Diagrams




Warning:

- a) A switch or circuit breaker must be connected between the network and the auxiliary supply input of device.
- b) Connected switch or circuit breaker must be in close proximity to the
- c) Connected switch or circuit breaker must be marked as the disconnecting device for the equipment.
- d) The type of the used fuse must be FF type and the current of the used fuse must be 1A.
- e) No need of a vantilator in the installation area
- f) Do not use with generator.


Dimensions




The Area Measurements on The Control Panel Wall Wall Wall



Control Panel Cut Out



Technical Data



Burden : <1 VA (per phase)

Output Contact : 5 A, 250 V, 1250 VA (Resistive) (for EVM-3C)

Voltage Transformer Ratio

Primary : 1-40000 (for EVM-3C) Secondary : 1-250 (for EVM-3C)

Ins. Tripping $:>1.5 \times SPH \text{ or } <0.5 \times SPL \text{ (for EVM-3C)}$

Hysteresis : 0-0.5 x Full scale (for EVM-3C) Delay Time : 0.0 - 999.9 sec. (for EVM-3C) : Non-flammable

Enclosure : Double Insulation (\square), **Equipment Protection**

Measuring CategoryIII Ambient Temperature : -5 °C; +50 °C

Degree of Protection : IP 40 (Front Panel)

Installations : Flush mounting with rear terminals

Wire Cross section (for terminals): 2.5 mm²

Dimensions : Type PR 18, PR 25, PR 20 Weight : 0.28 kg (for PR 18) 0.30 kg (for PR 25) 0.25 kg (for PR 20)

Packaging Information

Pcs per Package : 16 Pcs (for PR 18) Package Weight : 4.5 kg

Pcs per Package : 12 Pcs (for PR 25)

Package Weight : 3.6 kg

Pcs per Package : 20 Pcs (for PR 20)

Package Weight : 5 kg



- * Please check the device label for proper value.
- *Different supply voltages are adjustable upon request.



